CITY OF GERMANTOWN ATHLETIC FIELDS SCOREBOARDS ADDENDUM NO.3

The attached items on the above-named Project will be updated and adjusted (if required) by this Addendum No. 3 so as to reflect the revision to the Invitation to Bid:

1. Request for a different method of painting steel posts:

Answer: Yes. The City will accept different methods of painting posts. Therefore, the following specifications should be used:

The contractor shall furnish all labor, materials, and equipment required to complete the painting of the scoreboard support post. Painting can consist of spraying and/or brush/roller painting. If spraying, contractor must take necessary precautions to prevent over spray damaged to other surfaces and/or equipment.

All surfaces to be painted shall be dry and cleaned free of all dirt, grit, grease, mold, mildew, foreign substances and all loose, peeling, blistering, chalking or scaling of paint. All exposed rust and areas where rust indicated under the old paint film shall be removed to bare metal. Post must be primed with a suitable rust inhibitor. Posts shall be painted with exterior rust resistant type paint suitable for both ferrous & non-ferrous metal.

Contractor must provide make & grade of primer and paint to be used and methods of painting used on the back of the Bid Form page.

In some cases, the above items may be clarifications and further explanations of the Specifications in the Invitation to Bid. However, any <u>changes</u> to the Specifications will be incorporated in the Contract Documents for this Project. All BIDDERS must acknowledge receipt of this Addendum No. 2 on **the attached Addendum Acknowledgement form** when submitting a BID for consideration.

<u> Lisa A. Piefer</u>

November 15, 2012

Lisa A. Piefer Purchasing Officer

Date

ADDENDA ACKNOWLEDGEMENT FORM

BIDDER acknowledges receipt of the following addenda (as applicable):

Addendum No. 1	Dated
Addendum No. 2	Dated
Addendum No. 3	Dated
Addendum No. 4	Dated
Addendum No. 5	Dated
	(Name of Bidder)
	By:
	Title